

**BS EN 60598-2-2:2012**  
*Incorporating corrigendum March 2012*



BSI Standards Publication

# Luminaires

Part 2-2: Particular requirements  
— Recessed luminaires

**bsi.**

...making excellence a habit.™

### National foreword

This British Standard is the UK implementation of EN 60598-2-2:2012. It is identical to IEC 60598-2-2:2011. It supersedes BS EN 60598-2-2:1997, which will be withdrawn on 13 December 2014.

The UK participation in its preparation was entrusted by Technical Committee CPL/34, Lamps and Related Equipment, to Subcommittee CPL/34/4, Luminaires.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2012

Published by BSI Standards Limited 2012

ISBN 978 0 580 78535 1

ICS 29.140.40

### Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 29 February 2012.

### Amendments/corrigenda issued since publication

Amd. No.	Date	Text affected
	31 March 2012	Correction to supersession details

English version

**Luminaire  
 Part 2-2: Particular requirements -  
 Recessed luminaire**

(IEC 60598-2-2:2011)

Luminaire -  
 Partie 2-2: Règles particulières -  
 Luminaire encastrés  
 (CEI 60598-2-2:2011)

Leuchten -  
 Teil 2-2: Besondere Anforderungen -  
 Einbauleuchten  
 (IEC 60598-2-2:2011)

This European Standard was approved by CENELEC on 2011-12-13. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## CENELEC

European Committee for Electrotechnical Standardization  
 Comité Européen de Normalisation Electrotechnique  
 Europäisches Komitee für Elektrotechnische Normung

**Management Centre: Avenue Marnix 17, B - 1000 Brussels**

## Foreword

The text of document 34D/1030/FDIS, future edition 3 of IEC 60598-2-2, prepared by IEC/SC 34D, "Luminaires", of IEC/TC 34, "Lamps and related equipment" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60598-2-2:2012.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2012-09-13
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2014-12-13

This document supersedes EN 60598-2-2:1996 + A1:1997.

The changes introduced by EN 60598-2-2:2012 are those required to maintain consistency with later versions of EN 60598-1 that have been published since the previous edition of this standard.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

## Endorsement notice

The text of the International Standard IEC 60598-2-2:2011 was approved by CENELEC as a European Standard without any modification.

**Annex ZA**  
(normative)

**Normative references to international publications  
with their corresponding European publications**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60227	Series	Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V	-	-
IEC 60245	Series	Rubber insulated cables - Rated voltages up to and including 450/750 V	-	-
IEC 60598-1 -	-	Luminaires - Part 1: General requirements and tests	EN 60598-1	-

## CONTENTS

2.1	Scope.....	5
2.2	Normative references .....	5
2.3	General test requirements .....	5
2.4	Definitions .....	5
2.5	Classification of luminaires .....	5
2.6	Marking .....	5
2.7	Construction .....	5
2.8	Creepage distances and clearances .....	5
2.9	Provision for earthing .....	6
2.10	Terminals .....	6
2.11	External and internal wiring .....	6
2.12	Protection against electric shock .....	6
2.13	Endurance tests and thermal tests .....	6
2.14	Resistance to dust and moisture.....	7
2.15	Insulation resistance and electric strength .....	7
2.16	Resistance to heat, fire and tracking .....	7
Annex A (informative) Measurement of ambient temperature in an installation .....		8
Table 1 – Operating temperature of cable .....		7

## LUMINAIRES –

### Part 2-2: Particular requirements – Recessed luminaires

#### 2.1 Scope

This part of IEC 60598 specifies requirements for recessed luminaires incorporating electric light sources for operation from supply voltages up to 1 000 V. This section does not apply to air-handling or liquid-cooled luminaires.

#### 2.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60227 (all parts), *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V*

IEC 60245 (all parts), *Rubber insulated cables – Rated voltages up to and including 450/750 V*

IEC 60598-1, *Luminaires – Part 1: General requirements and tests*

#### 2.3 General test requirements

The provisions of section 0 of IEC 60598-1 apply. The tests described in each appropriate section of part 1 shall be carried out in the order listed in this section of part 2.

A procedure measuring ambient temperature in an installation is given in Annex A.

#### 2.4 Definitions

For the purposes of this document, the definitions of Section 1 of IEC 60598-1 apply.

#### 2.5 Classification of luminaires

Luminaires shall be classified in accordance with the provisions of Section 2 of IEC 60598-1.

#### 2.6 Marking

The provisions of Section 3 of IEC 60598-1 apply.

#### 2.7 Construction

The provisions of Section 4 of IEC 60598-1 apply.

#### 2.8 Creepage distances and clearances

The provisions of Section 11 of IEC 60598-1 apply.

## 2.9 Provision for earthing

The provisions of Section 7 of IEC 60598-1 apply.

## 2.10 Terminals

The provisions of Sections 14 and 15 of IEC 60598-1 apply.

## 2.11 External and internal wiring

The provisions of Section 5 of IEC 60598-1 apply.

Flexible cables or cords used as a means of connection to the supply, when supplied by the luminaire manufacturer, shall be at least equal in their mechanical and electrical properties to those specified in IEC 60227 or IEC 60245 and shall be capable of withstanding without deterioration the highest temperature to which they may be exposed under normal conditions of use. Materials other than p.v.c. and rubber are suitable if the above requirements are met.

*Compliance shall be checked by the tests specified in 2.13.*

NOTE The use of flexible cables and cords with recessed luminaires is appropriate for the following reasons:

- 1) The flexible cable or cord cannot be easily touched as it is normally out of reach within the recess.
- 2) To facilitate installation of the luminaire into the recess.
- 3) To permit the adjustment of settable and adjustable recessed luminaires.

## 2.12 Protection against electric shock

The provisions of Section 8 of IEC 60598-1 apply.

The parts of the luminaire and components within the ceiling space or cavity shall provide the same degree of protection against electric shock as the luminaire parts below the ceiling space.

NOTE The ceiling space or cavity is regarded as accessible for installation and maintenance, and the barriers do not provide adequate protection against electric shock.

*Compliance is checked by inspection.*

## 2.13 Endurance tests and thermal tests

The provisions of Section 12 of IEC 60598-1 apply together with the requirements of 2.13.1.

**2.13.1** Wiring, for connection to the supply, which passes into or can touch the luminaire shall not reach unsafe temperature.

*Compliance shall be checked by the following tests:*

*The luminaire is connected to the supply using the cable provided with the luminaire or using a cable in accordance with the marking on the luminaire or, if not marked, as specified in the manufacturer's instruction sheet; otherwise PVC cable complying with IEC 60227 is used.*

*The hottest point is found (along the internal route or on the outer surface of the luminaire) with which the cable is likely to lie in contact during normal service. The cable is lightly held in contact at this point and the temperature of the insulation at the point of contact is measured as described in Annex K of IEC 60598-1.*

*The operating temperature of the cable shall not exceed the limits given in Table 1.*



*Luminaires with an IP classification greater than IP20 shall be subjected to the relevant tests of Clauses 12.4, 12.5, 12.6 and 12.7 of Section 12 of IEC 60598-1 after the test(s) of Clause 9.2 but before the test(s) of Clause 9.3 of Section 9 of IEC 60598-1 specified in Clause 2.14 of this section of IEC 60598-2.*

**Table 1 – Operating temperature of cable**

Designation of cable	Limit of operating temperature
Cable (including sleeves) provided with the luminaire	The maximum temperature specified in Table 12.2 of IEC 60598-1
Cable not provided with the luminaire:	
a) luminaires with cable temperature marking	The marked temperature
b) luminaires without cable temperature marking	The maximum temperature specified in Table 12.2 of IEC 60598-1 for ordinary PVC not subject to mechanical stress

#### **2.14 Resistance to dust and moisture**

The provisions of Section 9 of IEC 60598-1 apply.

For luminaires with an IP classification greater than IP20, the order of the tests specified in Section 9 of IEC 60598-1 shall be as specified in Clause 2.13 of this section of IEC 60598-2.

#### **2.15 Insulation resistance and electric strength**

The provisions of Section 10 of IEC 60598-1 apply.

#### **2.16 Resistance to heat, fire and tracking**

The provisions of Section 13 of IEC 60598-1 apply.

## Annex A (informative)

### Measurement of ambient temperature in an installation

Considerable care is needed in deciding whether a recessed luminaire is operating within its thermal limits in an existing lighting installation. It is even more difficult to predict whether a luminaire will be satisfactory in a proposed installation and a "mock-up" is usually required. In the past, there have been instances of overheating of luminaires, for example, overheating owing to the presence of heating services above the ceiling plane.

The following procedure is for measuring the ambient temperature in which the luminaire operate. The  $t_a$  rating of the luminaire should be at least equal to this ambient temperature. The ambient temperature is measured in the plane of the ceiling (or other mounting surface) at the mid-point of a typical cavity. It is important that all other luminaires in the installation and all other services which may affect the thermal conditions of the luminaire are operating. The cavity is covered above the measuring point to prevent a non-typical interchange of air and so that the cover may absorb extraneous heat which would be absorbed by the luminaire.

NOTE It may be convenient to insert for this purpose the shell of the luminaire.

The test recess used to measure operating temperatures of recessed luminaires is intended to represent the most onerous closed recess (without other heat source) which is likely to be experienced in service. A recessed luminaire should not be installed in a cavity with a volume smaller than that of the test recess, unless the manufacturer of the luminaire has verified that operation will be satisfactory.

The test recess may also approximate to the thermal conditions above a suspended ceiling if the larger air volume is offset by heat-emitting services. In a particular installation, more onerous thermal conditions than this may exist and it is, therefore, essential to carry out a practical check. Conversely, the space above the ceiling may have free air movement and no heat-emitting services; for such an installation, the  $t_a$  rating of the luminaire as determined in the test recess incorporates a temperature margin and the  $t_a$  rating may be exceeded if the manufacturer of the luminaire has verified that operation in the particular installation will be satisfactory.

During tests, to determine or check a  $t_a$  rating for a luminaire, measurements of ambient temperature are made inside the draught-proof enclosure and outside the test recess in accordance with Annex K of IEC 60598-1.

---

<http://www.china-gauges.com/>

# British Standards Institution (BSI)

BSI is the national body responsible for preparing British Standards and other standards-related publications, information and services.

BSI is incorporated by Royal Charter. British Standards and other standardization products are published by BSI Standards Limited.

## About us

We bring together business, industry, government, consumers, innovators and others to shape their combined experience and expertise into standards-based solutions.

The knowledge embodied in our standards has been carefully assembled in a dependable format and refined through our open consultation process. Organizations of all sizes and across all sectors choose standards to help them achieve their goals.

## Information on standards

We can provide you with the knowledge that your organization needs to succeed. Find out more about British Standards by visiting our website at [bsigroup.com/standards](http://bsigroup.com/standards) or contacting our Customer Services team or Knowledge Centre.

## Buying standards

You can buy and download PDF versions of BSI publications, including British and adopted European and international standards, through our website at [bsigroup.com/shop](http://bsigroup.com/shop), where hard copies can also be purchased.

If you need international and foreign standards from other Standards Development Organizations, hard copies can be ordered from our Customer Services team.

## Subscriptions

Our range of subscription services are designed to make using standards easier for you. For further information on our subscription products go to [bsigroup.com/subscriptions](http://bsigroup.com/subscriptions).

With **British Standards Online (BSOL)** you'll have instant access to over 55,000 British and adopted European and international standards from your desktop. It's available 24/7 and is refreshed daily so you'll always be up to date.

You can keep in touch with standards developments and receive substantial discounts on the purchase price of standards, both in single copy and subscription format, by becoming a **BSI Subscribing Member**.

**PLUS** is an updating service exclusive to BSI Subscribing Members. You will automatically receive the latest hard copy of your standards when they're revised or replaced.

To find out more about becoming a BSI Subscribing Member and the benefits of membership, please visit [bsigroup.com/shop](http://bsigroup.com/shop).

With a **Multi-User Network Licence (MUNL)** you are able to host standards publications on your intranet. Licences can cover as few or as many users as you wish. With updates supplied as soon as they're available, you can be sure your documentation is current. For further information, email [bsmusales@bsigroup.com](mailto:bsmusales@bsigroup.com).

## BSI Group Headquarters

389 Chiswick High Road London W4 4AL UK

## Revisions

Our British Standards and other publications are updated by amendment or revision.

We continually improve the quality of our products and services to benefit your business. If you find an inaccuracy or ambiguity within a British Standard or other BSI publication please inform the Knowledge Centre.

## Copyright

All the data, software and documentation set out in all British Standards and other BSI publications are the property of and copyrighted by BSI, or some person or entity that owns copyright in the information used (such as the international standardization bodies) and has formally licensed such information to BSI for commercial publication and use. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI. Details and advice can be obtained from the Copyright & Licensing Department.

## Useful Contacts:

### Customer Services

**Tel:** +44 845 086 9001

**Email (orders):** [orders@bsigroup.com](mailto:orders@bsigroup.com)

**Email (enquiries):** [cservices@bsigroup.com](mailto:cservices@bsigroup.com)

### Subscriptions

**Tel:** +44 845 086 9001

**Email:** [subscriptions@bsigroup.com](mailto:subscriptions@bsigroup.com)

### Knowledge Centre

**Tel:** +44 20 8996 7004

**Email:** [knowledgecentre@bsigroup.com](mailto:knowledgecentre@bsigroup.com)

### Copyright & Licensing

**Tel:** +44 20 8996 7070

**Email:** [copyright@bsigroup.com](mailto:copyright@bsigroup.com)