



Small Finger Probe 5,6 Test Probe 19 of IEC 61032

IEC 61032 Figure 13 – Test probe 19 (small finger probe \varnothing 5,6)

- Finger: metal material
- Handle: insulating material

The extension of the handle represents the arm of the child.

The handle is provided with an extension, 464,3 mm long and the probe should be applied with or without this extension, whichever is the more onerous condition.

Both joints shall permit movement in the same plane and the same direction through an angle of 90°.

This probe is intended to simulate access to hazardous parts by children of 36 months or less.

g)

